



STEAM TRAP INSTALLATION  
See ADPC.01.2167

DIMENSIONS ( mm )

A	_____
B	_____
C	_____
D	_____
E	_____
F	_____
G	_____
H	_____

\* See IS catalogue.

By pass should not be installed if there is the risk of damage due to over pressure.

8.1	01	ADCA MAN-100 Pressure gauge	DN_____	Range _____ - _____ bar
08	01	ADCA MAN-100 Pressure gauge	DN_____	Range _____ - _____ bar
07	02	ADCA GC-400 Gauge Cock	DN_____	---
06	02	ADCA GSC-40 Gauge siphon	DN_____	---
05	01	Safety valve	DN_____	Spring _____
4.2	01	ADCA GV32B Globe valve	DN_____	---
4.1	01	ADCA GV32B Globe valve	DN_____	---
04	01	ADCA GV32B Globe valve	DN_____	---
03	01	ADCA IS16 Y Strainer	DN_____	---
02	01	ADCA S16S Humidify separator	DN_____	---
01	01	ADCA PRV25_____Pressure reducing valve	DN_____	* ---

Ref.	Quant.	Designation / Designação	Size/Medidas	Material	Remarks / Observações
Data		Rubrica		Proc. 0.490	
Proj. 06/11/07		F.Soares		---	
Des. 06/11/07		Paulo S.		---	
Verif.				---	
Escalas	Tolerancias n/ especificadas	Description / Descrição: PRESSURE REDUCING VALVE STATION CONJUNTO REDUTOR ARMADO PRV25 Series		Des.N°: <b>ADCR.01.2172</b>	
	Dimensões Desvios			Rev: 01 Em: 08/09/18	